

07 February 2019

Request for Proposal for Power Service RFP – 055/2018

Eurovision Song Contest 2019

Answers to Requests for Clarification – part 1

1. The answers to the requests for clarifications attached hereto as **Appendix A** are provided by ESC 2019 pursuant to section D.1 of the above Request for Proposals ("the **RFP**").
2. ESC 2019's responses below shall be deemed, for all intents and purposes, as part of the RFP and will bind all Respondents thereto but will not alter or derogate from the provisions of the RFP unless expressly stated otherwise.
3. These responses will be provided to all Respondents. Respondents must attach a copy of these responses, duly signed by an authorized signatory to indicate acceptance, to their Proposal.

KAN - the Israeli Broadcasting Corporation

We hereby confirm the contents of these **Answers to Requests for Clarification**, including our acknowledgement of any consequent changes to the RFP.

Respondent's signature

Appendix A – Answers to Clarification inquiries

	Article	Question	Answer
1		Can we get a sketch of all the positions and the generators locations in order to plan the cabling approximate lengths?	You shall be provided with the corresponding drawing once you have signed the NDA.
2		We could not find this drawing(s) within the downloaded files.	You shall be provided with the corresponding drawing once you have signed the NDA
3		Please can you supply a copy of the proposed contract to be signed following the completion of the RFP selection process so we can prepare ourselves if we will be chosen	The contract shall be provided to the successful Bidder
4		we missing some info to calculate the exact cable lengths: is there a pdf drawing available who shows the position of the generators and the 6 droppoints? Preferable also with some distances on it?	You shall be provided with the corresponding drawing once you have signed the NDA
5		cable crossing from generator compound to the venue: Will this needs to be done with yellow jackets? Must this be heavy duty for trucks passing over? Or will there be a bridge provided?	Cable crossings shall be done with the 500 yellow jackets you are providing as per Appendix 1: Standby Equipment tab. Trucks are not passing over the cables, but the yellow jackets we specified shall be heavy duty. No bridge will be provided
6		Green room: can this also be fed out of the large generator compound, or must this be a seperate compound?	This will be a separate compound next to the Green Room building
7		What is the distance, and must there be a also some cable protection provided?	You shall be provided with the corresponding drawing once you have signed the NDA. Supplier shall provide total amount of 500 yellow jackets as mentioned in Appendix 1, Standby Equipment tab.

8		dimmer and amp city's: are they on floor level, or up somewhere in the grandstands or roof?	You shall be provided with the corresponding drawing once you have signed the NDA
9		powerlock size: in the tender is marked 240 mm ² : may this be also 120 mm ² or 150 mm ² , taking in consideration the expected load and cable length?	240mm ² is an example to show that we would like to receive the pricing from you with the breakdown of the cables based on the different types. You can provide your calculations based on your ability to provide the necessary loads with the smaller power cables. During the evaluation, we will double check your estimations.
10		Ups systems: is a autonomy of 5 mins at 50 % of load sufficient?	UPS should be calculated as 5 mins on 100% load