

11 February 2019

Request for Proposal for Power Service RFP – 055/2018

Eurovision Song Contest 2019

Answers to Requests for Clarification – part 2

1. The answers to the requests for clarifications attached hereto as **Appendix A** are provided by ESC 2019 pursuant to section D.1 of the above Request for Proposals ("the **RFP**").
2. ESC 2019's responses below shall be deemed, for all intents and purposes, as part of the RFP and will bind all Respondents thereto but will not alter or derogate from the provisions of the RFP unless expressly stated otherwise.
3. These responses will be provided to all Respondents. Respondents must attach a copy of these responses, duly signed by an authorized signatory to indicate acceptance, to their Proposal.

KAN - the Israeli Broadcasting Corporation

We hereby confirm the contents of these **Answers to Requests for Clarification**, including our acknowledgement of any consequent changes to the RFP.

Respondent's signature

Appendix A – Answers to Clarification inquiries

	Article	Question	Answer
1		Can we place a synchronized generators and/or power unit instead of UPS system?	NO. All the generators for the Primary Power System need to be supplied as synchronized sets of generators. The purpose of the UPS power system is to compensate in the event that there is a failure of these synchronized sets of generators.
2		Is there a power requirement estimation for the project?	YES. Please refer to Appendix 1 which contains the Power outlet specifications for the primary power.
3		Is there a possibility of field visit, in order to understand the required physical route?	NO. The deadline for the submission of the proposal is in a few hours so please refer to the supplied drawings to obtain the information.
4		Can you postpone the proposal due date?	YES. Please note that the deadline for submitting proposals in the RFP for Power is postponed to Wednesday, 13.2.19, 15:00 Israel time
5			